

PO Box 707  
Kent Town SA 5071

42 Fullarton Rd  
Norwood SA 5067

P 08 8363 0222

F 08 8363 1555

ABN 58 083 071 185

fmgengineering.com.au

Ref: S20832 – 227637

17<sup>th</sup> March 2015

John Pierpoint & Brian Clarke  
ReGen Building Solutions

Dear Sirs,

**RE: Certificate of compliance – MEGABOARD cladding**

This document is provided as proof that FMG Engineering has examined testing materials pertaining to the cladding product 'MEGABOARD', provided by ReGen Building Solutions (formally AR Building Solutions) and certifies that, through these results, MEGABOARD is shown to comply with the following standards:

1. AS/NZS 2908.2:2000: Fibre Cellulose-cement products – Flat sheet, 'Type-A'.
2. AS1170.1:2002: Structural design actions Part 1: Permanent, imposed and other actions.
3. AS1170.2:2002: Structural design actions Part 2: Wind actions.
4. NCC Specification C1.8 when used in conjunction with design tables.
5. EN 13501-1: 2007: Non- combustibility and calorific value, 'Class A1'.
6. AS1530.4: Fire resistance of elements of building construction. Current testing indicates MEGABOARD will not be the critical element in design, further testing will be implemented for system details, in particular performance of fixings.

Yours sincerely



Rhys Flory  
BEng (Hons), MIE Aust.  
Project Structural Engineer  
**FMG Engineering incorporating Burns Hamilton**

Co-signed:



Serhan Halil  
BEng (Hons) CEng MStructE MIEAust CPEng  
Structural Team Principal  
**FMG Engineering incorporating Burns Hamilton**